



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.efectis.com

DECLARATION OF TEST RESULTS

No: EEA - 2400 - 0039

The fire resistance tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 29.08.2024 in accordance with the test standard:

EN 1634-1:2014+A1:2018

“DMK-FD-DL-F-I”

DOUBLE LEAF STEEL DOOR

FIRE RESISTANCE CLASSIFICATION

Direction: Opening away from the fire	E90, EI₂45, EI₁20
---------------------------------------	--

Placed on the market by: **DİMAK MAKİNE SANAYİ İNŞAAT VE TİCARET LTD.ŞTİ.**
Anadolu OSB 30 Ağustos Cad. No: 26 Sincan, Ankara / TÜRKİYE

Manufactured by: **DİMAK MAKİNE SANAYİ İNŞAAT VE TİCARET LTD.ŞTİ.**
Anadolu OSB 30 Ağustos Cad. No: 26 Sincan, Ankara / TÜRKİYE

e-signed
Ali BAYRAKTAR
Laboratory Manager
07.10.2024

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: EEA-24-069.

